

200 Amp 120/208 Three Phase

- Rate Schedule (W)
- Transformer Size (75 KVA)
- Voltage (120/208)

- Location to be determined at meeting

- Meter Height at Approx. 60"
- Ground to NEC and WI Comm 16
- Post- Minimum of 6" x 6" treated buried min. 3' in ground
- Backboards-5/4 Treated deck boards or larger (Must be new material, no plywood)

Chippewa Valley Supplies
 --Meter Socket
 --Milbank #U9701-XL 7-Terminal
 --Transformer/Cement Pad/Ground Sleeve
 --Meter
 --Secondary Wire (1 run of 4/0 Aluminum Quad)

Member Supplies
 -Service Rated Disconnect/Overload Protection with appropriate FCI Rating (Must be UL Listed)
 -Grounds
 -Conduit to be schedule 80 (2 1/2 " min) Back to Transformer to include sweeps and expansion joints as required. Buried at a min. of 24".

